



REPORT

issued by an Accredited Testing Laboratory

Contact person
Magnus Bobert
Fire Research
+46 10 516 51 90
magnus.bobert@sp.se

Date
2014-07-10

Reference
4P03406-7

Page
1 (1)



Dafo Fomtec AB
Box 683
135 26 Tyresö

Testing of foam concentrate according to ICAO-requirements, level C (1 appendix)

The department of Fire Research at SP Swedish National Testing and Research Institute has on your request performed tests of foam concentrate according to ICAO-requirements, Doc 9137-AN/898, Chapter 8.1.5, level C. The fire test, level C, was performed according to the revised ICAO Test Protocol dated July 2013.

Designation of foam concentrate:	AFFF 3% M
Type of foam concentrate:	AFFF
Samples:	IBC 1000 L. The sample has been send to SP from Dafo Fomtec AB. Batch No. 142190.
Manufactured by:	Dafo Fomtec AB
Date of arrival at SP:	May 23, 2014
Date of fire tests:	May 27, 2014
Date of chemical - physical tests:	June-July, 2014

Total results

The foam concentrate denoted AFFF 3% M fulfil the requirements stated in the ICAO-requirements, level C, when tested with 3% admixture as low expansion foam.

SP Technical Research Institute of Sweden Fire Research - Fire Dynamics

Performed by

Examined by

Magnus Bobert

Björn Sundström

Appendix

Test conditions and test results

SP Technical Research Institute of Sweden

Postal address
SP
Box 857
SE-501 15 BORÅS
Sweden

Office location
Västeråsen
Brinellgatan 4
SE-504 62 BORÅS

Phone / Fax / E-mail
+46 10 516 50 00
+46 33 13 55 02
info@sp.se

Laboratories are accredited by the Swedish Board for Accreditation and Conformity Assessment (SWEDAC) under the terms of Swedish legislation. This report may not be reproduced other than in full, except with the prior written approval of the issuing laboratory.

Appendix 1

Test conditions and test results

Physical properties

The physical properties were measured by SP Chemistry, Materials and Surfaces.

According to the customer the Lowest Use Temperature (LUT) is -6 °C.

Results of the physical properties

Parameter	Results	Requirements
pH-value	7,4	6,0 – 9,5
Sediment, vol %	<0,1	< 0,25
Viscosity, 20 °C	4,0 cSt	-
Viscosity, -6 °C	10,8 cSt	< 200 cSt
Refractive index	1,368	-

Expansion and drainage of foam

Test conditions: Ambient temperature: 21 °C

Premix temperature: 20 °C

Parameter	Results
Expansion ratio	9,2
Drainage 25 %, min:s	5:03
Drainage 50 %, min:s	7:39

Comments to the results of expansion and drainage of foam

No requirements are specified in the standard. The results are judged to be normal for this type of foam concentrate.

Appendix 1

Extinguishing tests according to ICAO-requirements , level C

The fire test was conducted indoors in the fire hall of SP.

<i>Designation</i>	Unit	AFFF 3% M
Date of test	y-m-d	2014-05-27
Admixture	%	3
Type of water		Fresh water
Foam nozzle UNI86	L min ⁻¹	11,4
Fire tray	m ²	7,32
Application rate	L m ⁻² min ⁻¹	1,6
Air temp.	°C	20
Fuel temp.	°C	17
Water temp.	°C	18
Foam solution temp.	°C	18
Wind speed	m/s	< 1
<i>Extinction</i>		
Type of fuel		Jet A1
Preburn time	min	1
Start foam application	min:s	00:00
90 % control	min:s	00:49
99 % extinguished	min:s	01:21
Extinguished	min:s	01:29
Stop foam application	min:s	02:00
<i>Burnback</i>		
Waiting period	min	2
Start burnback	min:s	00:00
Sustained fire in the tray	min:s	08:48
Burnback, > 25%	min:s	19:27

Requirements for extinguishing time and burnback time

At the 60 seconds time, minute flames (flickers) visible between the foam blanket and the inner edge of the tray are acceptable:

- If they don't spread in a cumulative length exceeding 25% of the circumference of the inner edge of the tray and:
- They are totally extinguished during the second minute of foam application.

Time to burnback: ≥ 5 minutes for 25% of the surface

Comments to the fire test results

At 60 seconds minute flames (flickers) were visible between the foam blanket and the inner edge of the tray with a cumulative length of about 1 m. The minute flames (flickers) decreased and the flames were totally extinguished at 1:29. The requirements are judged to be fulfilled.