

## CERTIFICATE OF CONFORMITY – FOAM CONCENTRATES

Certificate of conformity reference number: **KB 145/13**

**Test specification:** EN 1568-3 : 2008, EN 1568-4 : 2008

**Test report no.:** 2012-F-2946/Fm 12

**Requested by:** Dafo Fomtec AB, P.O. Box 683, SE-135 26 Tyresö, SWEDEN

**Manufacturer:** Dafo Fomtec AB, P.O. Box 683, SE-135 26 Tyresö, SWEDEN

**Name of the fire extinguishing medium:** Enviro 6x6 Plus

**Grade of foam concentrate:** Synthetic alcohol resistant foam concentrate (S-AR)  
according to annex A EN 1568

**Test fire performance:** Extinguishing performance and burn-back resistance:  
- Low expansion foam according to EN 1568-3 (6%)  
with potable water / with simulated sea water: I A / III B  
- Low expansion foam according to EN 1568-4 (6%) (alcohol resistant foam concentrate)  
with potable water / with simulated sea water: I A / I A (acetone)  
with potable water / with simulated sea water: I A / I A (isopropanol)

**Freezing point:** - 6,5 °C

**Notes:** Pseudoplastic foam concentrate. The use of this foam concentrate may require special dosage equipment.


Conformity to the above mentioned test specification is attested. All applicable requirements have been met.

This certificate of conformity is valid solely for foam concentrates which correspond to the submitted test samples and to the confirmed documents.

Certificates of conformity of fire extinguishers are solely valid in conjunction with the fire extinguishing medium the type test of the fire extinguisher has been done with.

This certificate of conformity does not include surveillance.

24<sup>th</sup> June 2013



Grad. Eng. Jürgen Dittrich  
Laboratory Manager

